## 1. Roads / Sidewalks

- a) Install new catch basin and drain line at intersection 49 st & 53 Ave
- b) Repair water line repair excavations with cold mix 50 st, 53 ave and 46 st
- c) Pack down bumps on 52 Ave between 50 st and 51 st
- d) Clean out drainage ditches in industrial park
- e) Fill potholes on most streets and avenues
- f) Grade Geleta park
- g) Repair washout along sidewalk on 48 st north at 51 ave
- h) Install 24" culvert at Bumper to Bumper access
- i) Paint crosswalks
- j) Grade and pack washboard on 51 ave between 48 & 49 st
- k) SB90 oil ordered for third week of August

## 2. Water/Wastewater

- a) Sewer camera and record at Hillside Lodge as per request
- b) Checked pipe sweating at apartments
- c) Checked pipe sweating and shop vacd dental office as per request
- d) Install 1" water line to ball diamonds
- e) Power failure backup pump ran approx. 1 hour
- f) RV Dump backed up, vacd and flushed
- g) 46<sup>th</sup> ave flushed eastward
- h) Lift station back up generator test failed-troubleshooted & found to be distributor problem, repaired by PEAK
- i) 2" copper service line to Rudyks well pumphouse excavated, capped and abandoned for pumphouse removal

## 3. Other

- a) Remove pump shack
- b) Remove sod and replace with rock at Town Office
- c) Weed whip and spray grass along sidewalks
- d) Service and repair sweeper
- e) Install new tires on sweeper
- f) Repairs on hall west wall
- g) Install new doors on hall
- h) Pick up new Public Works trucks from Vegreville
- i) Roof repair and door replacement at public works shop as well as roof over public works office to begin soon
- j) Sweep parade route
- k) Removed straw waddles from the ditches along highway 45 & 36
- I) Service lift station generator
- m) Attend ACE water meeting
- n) Attend emergency planning course
- o) Mow and weed whip all Town grass
- p) Sidewalk replacement to being third week of August