

Public Works Foreman Report

April 11, 2017

1) Roads

- a) Haul all snow windrows off roads;
- b) Haul 50 yds. of crushed concrete to 55 Ave and 51 St and grade;
- c) Haul 160 yds. crushed concrete to 45 Ave between 54 and 53 St, grade and pack;
- d) Gravel and grade east side of curling rink and west side of arena;
- e) Clean out drainage ditches on the three back alleys on the south side of 46 Ave;
- f) Repair all waterline break repair evacuation sites with dry material;
- g) Grade 53 Ave east of 48 St.

2) Water/Wastewater

- a) Continue to monitor wastewater lagoons, south side water pressure, known problem areas with sanitary system, and storm sewer system;
- b) March 29 - Back-up generator at sanitary lift station start up with PEAK and gauges checked;
- c) Service call with sewer camera to residence in Duvernay;
- d) Checked and changed residential meter;
- e) March 31 - Discovered water break on 47 Ave at night; 1 resident affected and sanitary lift station; isolated break and calls to Alberta Environment and Alberta One Call were made; Repair was made on Monday April 3 with water provided daily to the resident.
- f) April 3 – Power failure occurred and with no water for the generator at the sanitary lift station, the safety shut-off was engaged and shut down the power plant. Due to the power outage and surges, the following damages were noticed: burnt fuses in the generator panel, automatic switch, alarm dial out, back up battery, furnace transformers, light ballasts.

3) Other

- a) Remove damaged sidewalk on 45 Ave and filled with gravel;
- b) Repair lights and furnace in lift station;
- c) Steam and vac out main water valves on 46 Ave, 50 Ave, and 49 St;
- d) Remove ice from arena.