

1) Roads

- a) Complete road work on 49 street with concrete and asphalt.
- b) Replace part of the culvert at the corner of 53rd street and 46th Avenue.
- c) Grade industrial road 51st to 57th Avenue with some concrete.
- d) Repair drainage ditch on north side of 55 Avenue.
- e) Fill pot holes on 50th street between 50th Avenue and 54th Avenue.
- f) Grade 45th Avenue from 52nd to 54th street with some concrete.

2) Water/Wastewater

- a) CC locate and water line freeze as per resident request – CC will need repair.
- b) Water service restored on 49th street – CC valves lowered.
- c) Pump house CL2 analyzers calibrated.
- d) PRV vault vacuumed out.
- e) Problem manhole on 51st St and 52nd Ave checked and vacuum out.
- f) Dig and replace faulty CC valve at 5022 – 47 Ave location.
- g) Locate and mark main vales and manholes for reclaimer.
- h) Alberta Environment visited reservoir – took chlorine test.
- i) Power failure – all back up system on line, power surge caused some issues at reservoir pump house; rebooted security system and online monitoring systems. Orientation of back flow preventers and shut off to municipal system within new Mennonite school.

3) Other

- a) Vacuum out trench in arena.
- b) Start-up ice plant repairs and inspection on October 3, 2017.
- c) Sidewalk lifts completed at 4818 - 54 street and 4816 – 54 street (picture of before and after attached).
- d) Serviced and winterized equipment.
- e) Complete service requests.