

a) Roads

- a. Grade 51 St. North of Highway 45.
- b. Grade 54 Ave between 49 St. and 48 St.
- c. Grade 52 St. North of 50 Ave.
- d. Grade back alleys South of Highway 45 from 51 St to 46 St and the one North of 50 Ave.
- e. Grade parking lot at Hall and Rec Centre.
- f. Start road sweeping on Main Street, 53 St South side, 50 Ave from 52 St to 49 St and Highway 36.
- g. Fill major pot holes with SB90.
- h. Repair water line excavation with SB90.
- i. Dig out soft spots on 49 St North of 51 Ave and packed with gravel.

b) Water/Wastewater

- a. Monitoring sanitary flow rates at lifts station.
- b. 47 Ave water break (alerted by low pressure alarm) located excavated and repaired, temporary potable water provided from reservoir pump house over the weekend.
- c. Monitoring river levels as to potential lift station flooding discussed; containment options.
- d. Pinhole water leak by County Office located, excavated and repaired.
- e. Considerable ground water penetration into dry cell monitoring sump pump.
- f. Set up County Fire Department with their own code for truck filling at reservoir.
- g. Backup sanitary service at Burger Palace steamed from manhole flow restored.
- h. Two-hour power failure at lift station monitored by Terry Public Works Foreman.
- i. Second water break on 47 Ave located excavated and repaired.

c) Other

- a. Replace traffic signs along 51 St that were knock down.
- b. Repair and service street sweeper, sweeper broom on loader, packers, and mowing equipment.
- c. Complete all service requests.

d) Recommendations

- a. Roadway on 53 Avenue west of Highway 36 – Road is 45' wide from the gutter to the north edge of the road. Distance between parked vehicles on the road surface is 23'; providing ample room for driving lanes.
- b. Sidewalk on 52 Avenue (north side) west of Highway 45 should not be removed. There is no sidewalk on the south side of the road; approximately 200' of sidewalk should be replace. There is a fair amount of pedestrian traffic from Eventide and residents.