

- 1) Roads
  - a) Grade and haul snow from all streets and avenues.
  - b) Grade industrial park roads.
  - c) Grade all back alleys.
  - d) Sand roads and intersection as required.
  - e) Remove snow from east side of arena.
  - f) Clean parking lot at the Hall.
  
- 2) Water/Wastewater
  - a) Calibrated distributor and ACE Cl2 analyzers.
  - b) 5012 – 50 Ave Main break. AB ENV – Notified 1<sup>st</sup> calls done, excavated and repaired. 1 circular break and 2 holes; filled excavation, flushed from 3 locations, Cl2 and 3 BACTI samples taken approx. loss 370 m3.
  - c) Vac'd and cleaned library basement due to water break.
  - d) Flushed and vac'd 50 Ave sanitary main 450 feet east from Highway 36.
  - e) Flushed and vac'd 52 – 51<sup>st</sup> Ave approximately 375 feet.
  - f) Flushed sewer mains 45 Ave from the Arena east to 53 St. and north to 46 Ave.
  - g) Flushed sewer mains 47 St to 52 Ave and 52 Ave to 51 Ave.
  - h) DR 890 portable Cl2 test kits sent for annual inspection.
  - i) Posted water rate increase at truck fill.
  - j) Completed service requests: Sewer camera residential service and thawed frozen residential service who is on the drip list.
  
- 3) Other
  - a) Vac truck re-certified.
  - b) Tandem axel and single axel dump truck re-certified.
  - c) Replace rear brake drums and breaks shoes on sanding truck.
  - d) Meet with select Engineering to install by pass line at the lifts station.
  - e) Order lifts station pump.
  - f) Sweep and salt town sidewalks.
  - g) Complete all service requests.