

Public Works Foreman Report

January 10, 2017

1) Roads

- a) Sand all roads;
- b) Grade industrial roads, 51 St. from 55 to 57 Ave;
- c) Remove ice from sidewalk and 51 St. after water break at 5008-51 St. was repaired;

2) Water/Wastewater

- a) Continue to monitor lagoons, furnaces, south side water pressure and main line from the hospital;
- b) Water break at 5008-51 St. - repaired leak and vac'd cellar, cleaned ice water from the property as well as the neighbouring property (at cost to homeowner);
- c) Water break on 55 Ave on Christmas Day, excavated main valve and replaced rusted bolts with stainless steel bolts and replaced gasket.
- d) Water break on 50 Ave evening of January 3, crews worked late trying to isolate the break, residents were without water for approximately 5 hours on January 4 while repair was completed at 4801-50 Ave.

3) Other

- a) Haul all concrete from Krahn's Welding yard to lagoon concrete pile;
- b) Install lid stoppers on 70 garbage bins;
- c) Install sump pump and hose in curling rink header;
- d) Install new keyed door knobs for Janitor room and furnace rooms at the Centennial Hall;
- e) Repaired chimney at the Centennial Hall
- f) Vac water from the PRV valve at 50 Ave.
- g) Complete all service requests.